

Memorandum for the Record

STATINTL

Subject : Contract [REDACTED] 7015-77

A-E STUDY OF AIR CONDITIONING FACILITIES,

STATINTL

1. The Mechanical Equipment Room that is being considered for use as a second MAX enclosure is presently utilized as a housing for the air handlers which provide proper ventilation for the building complex.

2. If this Mechanical Equipment Room becomes the location of the second MAX enclosure, it is proposed that a Mechanical Equipment Room be constructed to house all the necessary mechanical equipment required to support the building complex. The high cost of constructing a separate mechanical equipment room and the cost of relocating equipment does not prove to be a cost effective means of obtaining the limited amount of additional operating space.